


<b>F9</b>	<b>SHEET NOTES</b>
-----------	--------------------


- 1 RE-FRAME EXISTING OPENING WITH 2x4 HEM-FIR #2 AT 24" C/C. ATTACH WITH SIMPSON STRONG TIE LUS28. COVER WITH 5/8" APA RATED SHEATHING WITH 10d GALVANIZED BOX NAILS AT 6" C/C AT PANEL EDGES AND AT 12" C/C AT INTERMEDIATE SUPPORTS.
- 2 INFILL EXISTING FRAMED OPENING WITH 2x4 HEM-FIR #2 AT 24" C/C. ATTACH WITH SIMPSON STRONG TIE LUS24. COVER WITH 5/8" APA RATED SHEATHING WITH 10d GALVANIZED BOX NAILS AT 6" C/C AT PANEL EDGES AND AT 12" C/C AT INTERMEDIATE SUPPORTS.
- 3 PROVIDE (2) ROWS OF BLOCKING BETWEEN NEW JOISTS AT EDGE OF NEW HVAC UNIT.
- 4 PROVIDE 3 1/8x18 GLB BLOCKING BETWEEN EXISTING GLUE-LAM BEAMS. ATTACH NEW GLUE-LAM BEAMS TO BLOCKING WITH SIMPSON STRONG TIE HU212-2.
- 5 ATTACH NEW GLUE-LAM BEAMS TO EXISTING WITH SIMPSON STRONG TIE HU212-2, TYPICAL.
- 6 NAIL SHEATHING AT 12" C/C, FULL LENGTH, TYPICAL.
- 7 2x4 FRAMING, TYPICAL AT NEW HVAC PENETRATIONS. NAIL SHEATHING TO NEW BLOCKING WITH 10d GALVANIZED BOX NAILS AT 6" C/C.
- 8 INSTALL 2x4 BLOCKING AND COVER EXISTING PENETRATIONS WITH PLYWOOD TO MATCH EXISTING.
- 9 2x4 FRAMING, TYPICAL AT NEW EXHAUST FAN PENETRATIONS.
- 10 PROVIDE (2) 2x10 BLOCKING AROUND NEW HVAC OPENING AND ATTACH WITH SIMPSON STRONG TIE LUS 210-2, EACH SIDE.

<b>D9</b>	<b>FLAG NOTES</b>
-----------	-------------------



**DESIGN WEST**  
ARCHITECTS, P.A.  
7513 W KENNEDICK AVE SUITE D  
KENNEICK, WA 98036  
PH. (509) 783-2244 FAX (509) 783-8740

© COPYRIGHT DESIGN WEST ARCHITECTS P.A.  
DESIGN CONCEPTS AND DRAWINGS NOT TO BE REUSED  
WITHOUT WRITTEN PERMISSION OF ARCHITECT



**Meier**  
ARCHITECTURE/ENGINEERING

8697 Gage Boulevard  
Kennewick, WA 99136

P: 509.735.1589  
F: 509.783.5075  
JOB NO: 7056

CAD FILE: 705600S141.dwg

**KENNEWICK SCHOOL DISTRICT**  
**1315 BUILDING RENOVATIONS**  
1315 WEST 4TH AVENUE  
KENNEWICK, WA.  
99338

REVISIONS
DRAWN BY: MB6
CHECKED BY: JTS
DATE 1/10/2013
JOB NUMBER 1278

**SHEET NAME**

**ROOF  
FRAMING PLAN**

SHEET  
**\$1.41**

**A1**      **ROOF FRAMING PLAN**

$$1/8'' = 1'-0''$$