


SHEET NOTES:


1. FINAL LOCATION OF EQUIPMENT DISCONNECTS/ CONTROLLERS SHALL BE COORDINATED WITH ALL TRADES PRIOR TO ROUGH-IN. NEC REQUIRED CLEARANCES SHALL BE MAINTAINED. A UNISTRUT ASSEMBLY SHALL BE CONSTRUCTED FOR ALL DISCONNECTS/ CONTROLLERS AND RECEPTACLES WHICH CAN NOT BE LOCATED ON BUILDING STRUCTURE. PROVIDE ALL MATERIALS REQUIRED.
2. SEE MECHANICAL SCHEDULES ON SHEET E0.03 FOR ADDITIONAL INFORMATION.
3. HOMERUNS FOR ROOF TOP MECHANICAL EQUIPMENT AND RECEPTACLES MOUNTED AT MECHANICAL EQUIPMENT SHALL BE ROUTED DOWN THROUGH ROOF WITHIN MECHANICAL UNIT ROOF CURB. RACEWAY SHALL NOT PENETRATE ROOF SURFACE.
4. ALL J-BOXES FOR DEVICES ON ROOF SHALL BE NEMA-3R.

FLAG NOTES:

- 1 INSTALL MOTOR RATED TOGGLE INSIDE EXHAUST FAN HOUSING.
- 2 UNIT IS FURNISHED WITH FACTORY INSTALLED SERVICE RECEPTACLE WHICH IS PART OF SINGLE POINT POWER CONNECTION TO UNIT.
- 3 CONNECT RECEPTACLE ON LINE SIDE OF DISCONNECT. INSTALL RECEPTACLE INSIDE EXHAUST FAN HOUSING.



DESIGN WEST
ARCHITECTS P.A.
7515 W. KENNEDY AVE. SUITE D
KENNEWICK, WA 98336
PH. (509) 783-2244 FAX (509) 783-8740
© COPYRIGHT DESIGN WEST ARCHITECTS P.A.
DESIGN AND CONSTRUCTION DOCUMENTS
WITHOUT WRITTEN PERMISSION OF ARCHITECT



HARGIS
Hargis Engineers, Inc.
600 Stewart Street, Suite 1000 | Seattle, WA 98101
T | 206.448.3376 | 206.448.4450 w | hargis.biz
ENGINEERS | MECHANICAL | ELECTRICAL | TELECOMMUNICATIONS

KENNEWICK SCHOOL DISTRICT
1315 BUILDING RENOVATIONS
1315 WEST 4TH AVENUE
KENNEWICK, WA. 98336

REVISIONS
DRAWN BY: JPH DB
CHECKED BY: MLR
DATE 2/19/2012
JOB NUMBER 278
SHEET NAME POWER ROOF PLAN

SHEET
E3.02