


SHEET NOTES:


1. FIRE ALARM DRAWINGS DEPICT OWNER'S MINIMUM REQUIREMENTS. CONTRACTOR IS RESPONSIBLE FOR COORDINATING ALL REQUIREMENTS WITH AHJ AND PROVIDING ALL CONDUIT, WIRING, DEVICES AND EQUIPMENT REQUIRED FOR A COMPLETE AND APPROVED SYSTEM.
2. COORDINATE ALL INTERIOR & EXTERIOR DEVICE LOCATIONS WITH ARCHITECTURAL ELEVATIONS. COORDINATE ALL CONFLICTS WITH A/E PRIOR TO ROUGH-IN.
3. FIRE ALARM CONDUIT AND CABLING ROUTING SHALL FOLLOW THE OTHER GENERAL PATHWAYS AND GUIDELINES SET FORTH IN THE LIGHTING AND POWER FLOOR PLAN SHEETS, UNLESS OTHERWISE NOTED.
4. SEAL ALL EXTERIOR WALL PENETRATIONS WITH APPROVED FIRE PROOFING MATERIALS.

FLAG NOTES:

1. CONNECT NEW PHONE LINE TO NEW FIRE ALARM CONTROL PANEL DIALER. PROVIDE APPURTENANCES REQUIRED TO INTERFACE WITH BUILDING EMCS AND SECURITY PANEL.
2. PROVIDE SURFACE MOUNTED NEMA-3R J-BOX FOR DEVICE AS INDICATED. PENETRATE EXTERIOR WALL AND ROUTE CONDUIT OUT OF BACK OF BOX INTO ACCESSIBLE CEILING SPACE. SEAL EXTERIOR PENETRATION WITH FIRE PROOFING MATERIALS.



DESIGN WEST
ARCHITECTS, P.A.
7513 KENNEDY AVENUE, SUITE 100
KENNEWICK, WA 98548
PH: (509) 783-2244 FAX: (509) 783-8740
© COPYRIGHT DESIGN WEST ARCHITECTS P.A.
DESIGN CONCEPTS AND DRAWINGS NOT TO BE REPRODUCED
WITHOUT WRITTEN PERMISSION OF ARCHITECT



HARGIS
Hargis Engineers, Inc.
600 Stewart Street, Suite 1000 | Seattle, WA 98101
1 | 206.448.3376 | 1 | 206.448.4450 | w | hargis.biz
ENGINEERS | MECHANICAL ELECTRICAL TELECOMMUNICATIONS

**KENNEWICK SCHOOL DISTRICT
1315 BUILDING RENOVATIONS**
1315 WEST 4TH AVENUE
KENNEWICK, WA 98536

REVISIONS

DRAWN BY:
JPH, DB

CHECKED BY:
MLR

DATE
2/9/2012

JOB NUMBER
278

SHEET NAME

**FIRST FLOOR
AND
MEZZANINE
LOW-VOLTAGE
FLOOR PLANS**

SHEET

E5.01

A1 FIRST FLOOR LOW-VOLTAGE FLOOR PLANS

SCALE 1/8" = 1'-0"

A8 MEZZANINE LOW-VOLTAGE FLOOR PLANS

SCALE 1/8" = 1'-0"